



Presented to:
Energy Forum

HOMER
Energy Simulation
Demonstration



TECHNOLOGY DRIVEN. WARFIGHTER FOCUSED.

August 2013

Presented by:

Bill Pannell

**AMRDEC Energy and Environment Lab Mgr
U.S. Army Aviation and Missile Research,
Development, and Engineering Center**

HOMER Energy Simulation Tool Demo

Setting the stage

- **Terminology**
 - **Power** Watts, kilowatts (kW)
 - **Energy** kilowatt hours (kW hr), or British Thermal Unit (BTU)
- **This Example Application of Homer vs Other Uses of HOMER**
 - **Not hooked to power grid, such as military forward operating bases**
 - **Similar to some cabins that are off the grid**
 - **HOMER can work grid tied problems too**



HOMER - [FOB_DieselOnly]

File View Inputs Outputs Window Help

Equipment to consider dd/Remove Calculate Simulations: 0 of 3 Progress:
 Sensitivities: 0 of 1 Status:

Sensitivity Results | Optimization Results

Double click on a system below for optimization results.

		Gen (kW)	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Diesel (L)	Gen (hrs)
		10	\$ 10,000	19,526	\$ 259,613	0.958	0.00	13,829	8,759

Resources: Diesel, Economics, System Control, Emissions, Constraints

Warnings:

Document: Author:
 Notes:

Focus on red boxes in this ppt "demo"

Generator Inputs

File Edit Help



Choose a fuel, and enter at least one size, capital cost and operation and maintenance (O&M) value in the Costs table. Note that the capital cost includes installation costs, and that the O&M cost is expressed in dollars per operating hour. Enter a nonzero heat recovery ratio if heat will be recovered from this generator to serve thermal load. As it searches for the optimal system, HOMER will consider each generator size in the Sizes to Consider table.

Hold the pointer over an element or click Help for more information.

Cost Fuel Schedule Emissions

Fuel curve

Fuel Diesel

Intercept coeff. (L/hr/kW rated)

Slope (L/hr/kW output)

Advanced

Heat recovery ratio (%)

Cofire with biogas

Substitution ratio

Minimum fossil fraction (%)

Derating factor (%)



Generator Inputs

File Edit Help



Choose a fuel, and enter at least one size, capital cost and operation and maintenance (O&M) value in the Costs table. Note that the capital cost includes installation costs, and that the O&M cost is expressed in dollars per operating hour. Enter a nonzero heat recovery ratio if heat will be recovered from this generator to serve thermal load. As it searches for the optimal system, HOMER will consider each generator size in the Sizes to Consider table.

Hold the pointer over an element or click Help for more information.

Cost Fuel Schedule Emissions

Costs


Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/hr)
3.000	3000	3000	0.100
5.000	5000	5000	0.167
10.000	10000	10000	0.334
{.}	{.}	{.}	{.}

Sizes to consider

Size (kW)
3.000
5.000
10.000
{.}

Properties

Description Type AC
 DC
 Abbreviation
 Lifetime (operating hours) {.
 Minimum load ratio (%) {.



Help

Cancel

OK

HOMER - [FOB_DieselOnly]





File View Inputs Outputs Window Help

Equipment to consider






Simulations: 0 of 3 Progress:
Sensitivities: 0 of 1 Status:

Sensitivity Results | Optimization Results

Double click on a system below for optimization results.

		Gen (kW)	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Diesel (L)	Gen (hrs)
		10	\$ 10,000	19,526	\$ 259,613	0.958	0.00	13,829	8,759

Resources


-  Diesel
-  Economics
-  System Control
-  Emissions
-  Constraints



Warnings

Document

Author

Notes

 Generator 1

-  RDISS+FP Suite
48 kWh/d
3.9 kW peak
-  ECP
10 kWh/d
AC 1.9 kW peak

Primary Load Inputs

File Edit Help



Choose a load type (AC or DC), enter 24 hourly values in the load table, and enter a scaled annual average. Each of the 24 values in the load table is the average electric demand for a single hour of the day. HOMER replicates this profile throughout the year unless you define different load profiles for different months or day types. For calculations, HOMER uses scaled data: baseline data scaled up or down to the scaled annual average value.




Hold the pointer over an element or click Help for more information.

Label: Load type: AC DC Data source: Enter daily profile(s) Import time series data file

Baseline data

Month: Day type:

Hour	Load (kW)
00:00 - 01:00	2.000
01:00 - 02:00	2.000
02:00 - 03:00	2.000
03:00 - 04:00	2.000
04:00 - 05:00	2.000
05:00 - 06:00	2.000
06:00 - 07:00	2.000
07:00 - 08:00	2.000
08:00 - 09:00	2.000
09:00 - 10:00	2.000
10:00 - 11:00	2.000
11:00 - 12:00	2.000
12:00 - 13:00	2.000
13:00 - 14:00	2.000
14:00 - 15:00	2.000



Time step (minutes):
 Random variability: Day-to-day % Time-step-to-time-step %
 Scaled annual average (kWh/d): {.}

	Baseline	Scaled
Average (kWh)	48.0	47.6
Average (kW)	2.00	1.98
Peak (kW)	3.89	3.86
Load factor	0.514	0.514

HOMER - [FOB_DieselOnly]

File View Inputs Outputs Window Help

Equipment to consider dd/Remove

```

graph LR
    G1[Generator 1] --> RDISS[RDISS+FP Suite  
48 kWh/d  
3.9 kW peak]
    G1 --> ECP[ECP  
10 kWh/d  
AC 1.9 kW peak]
    
```

Simulations: 0 of 3 Progress:
 Sensitivities: 0 of 1 Status:

Sensitivity Results | Optimization Results

Double click on a system below for optimization results.

		Gen (kW)	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Diesel (L)	Gen (hrs)
		10	\$ 10,000	19,526	\$ 259,613	0.958	0.00	13,829	8,759

Resources

- Diesel
- Economics
- System Control
- Emissions
- Constraints

Warnings

Document

Author

Notes

Primary Load Inputs

File Edit Help



Choose a load type (AC or DC), enter 24 hourly values in the load table, and enter a scaled annual average. Each of the 24 values in the load table is the average electric demand for a single hour of the day. HOMER replicates this profile throughout the year unless you define different load profiles for different months or day types. For calculations, HOMER uses scaled data: baseline data scaled up or down to the scaled annual average value.

Hold the pointer over an element or click Help for more information.

Label



Load type: AC DC

Data source: Enter daily profile(s) Import time series data file


Baseline data

Month

Day type



Hour	Load (kW)
00:00 - 01:00	0.100
01:00 - 02:00	0.100
02:00 - 03:00	1.000
03:00 - 04:00	0.100
04:00 - 05:00	0.100
05:00 - 06:00	1.000
06:00 - 07:00	1.000
07:00 - 08:00	0.100
08:00 - 09:00	1.000
09:00 - 10:00	0.100
10:00 - 11:00	0.100
11:00 - 12:00	1.000
12:00 - 13:00	0.100
13:00 - 14:00	1.000
14:00 - 15:00	0.100



Time step (minutes)

Random variability

Day-to-day %

Time-step-to-time-step %

Scaled annual average (kWh/d)

	Baseline	Scaled
Average (kWh)	10.5	10.5
Average (kW)	0.438	0.437
Peak (kW)	1.94	1.94
Load factor	0.226	0.226

Simulation Results

System Architecture: 10 kW Generator 1

Total NPC: \$ 259,613
 Levelized COE: \$ 0.958/kWh
 Operating Cost: \$ 19,526/yr

Cost Summary | Cash Flow | Electrical | Gen | Emissions | Time Series

Quantity	Value	Units
Hours of operation	8,759	hr/yr
Number of starts	2	starts/yr
Operational life	1.71	yr
Capacity factor	31.2	%
Fixed generation cost	1.64	\$/hr
Marginal generation cost	0.200	\$/kWh

Quantity	Value	Units
Electrical production	27,290	kWh/yr
Mean electrical output	3.12	kW
Min. electrical output	3.00	kW
Max. electrical output	5.79	kW

Quantity	Value	Units
Fuel consumption	13,829	L/yr
Specific fuel consumption	0.507	L/kWh
Fuel energy input	136,077	kWh/yr
Mean electrical efficiency	20.1	%



HOMER - [FOB battery inverter]

File View Inputs Outputs Window Help





Equipment to consider .dd/Remove


Calculate Simulations: 0 of 63 Progress:

Sensitivities: 0 of 1 Status:

Sensitivity Results | Optimization Results

Double click on a system below for optimization results.

	Gen (kW)	L16P	Conv. (kW)	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Diesel (L)	Gen (hrs)
   	3	10	5	\$ 5,500	9,262	\$ 123,905	0.457	0.00	7,536	8,751



Resources: Diesel

Other: Economics, System Control, Emissions, Constraints

Battery Inputs

File Edit Help



Choose a battery type and enter at least one quantity and capital cost value in the Costs table. Include all costs associated with the battery bank, such as mounting hardware, installation, and labor. As it searches for the optimal system, HOMER considers each quantity in the Sizes to Consider table.

Hold the pointer over an element or click Help for more information.

Battery type

Battery properties


Manufacturer: Trojan Battery Company Lifetime throughput: 1,075 kWh
 Website: www.trojan-battery.com
 Nominal specs: 6 V, 360 Ah, 2.16 kWh

Costs

Quantity	Capital (\$)	Replacement (\$)	&M (\$/yr)
1	200	200	10.00

Sizes to consider

Batteries
1
5
10
20
30
40
50



Advanced

Batteries per string (6 V bus)
 Initial state of charge (%)
 Minimum battery life (yr)

HOMER - [FOB battery inverter]

File View Inputs Outputs Window Help





Equipment to consider .dd/Remove


Simulations: 0 of 63 Progress:

Sensitivities: 0 of 1 Status:

Sensitivity Results | Optimization Results

Double click on a system below for optimization results.

	Gen (kW)	L16P	Conv. (kW)	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Diesel (L)	Gen (hrs)
   	3	10	5	\$ 5,500	9,262	\$ 123,905	0.457	0.00	7,536	8,751



Resources: Diesel

Other: Economics, System Control, Emissions, Constraints

Converter Inputs

File Edit Help



A converter is required for systems in which DC components serve an AC load or vice-versa. A converter can be an inverter (DC to AC), rectifier (AC to DC), or both.

Enter at least one size and capital cost value in the Costs table. Include all costs associated with the converter, such as hardware and labor. As it searches for the optimal system, HOMER considers each converter capacity in the Sizes to Consider table. Note that all references to converter size or capacity refer to inverter capacity.

Hold the pointer over an element or click Help for more information.


Costs

Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/yr)
5.000	500	500	10

{.}	{.}	{.}
-----	-----	-----

Sizes to consider

Size (kW)
0.000
5.000
10.000



Inverter inputs

Lifetime (years) {.}

Efficiency (%) {.}

Inverter can operate simultaneously with an AC generator

Rectifier inputs

Capacity relative to inverter (%) {.}

Efficiency (%) {.}

Help

Cancel

OK

Simulation Results

System Architecture: 3 kW Generator 1 5 kW Rectifier
 10 Trojan L16P Cycle Charging
 5 kW Inverter


Total NPC: \$ 123,905
 Levelized COE: \$ 0.457/kWh
 Operating Cost: \$ 9,262/yr

Cost Summary | Cash Flow | Electrical | Gen | Battery | Converter | Emissions | Time Series

Quantity	Value	Units
Hours of operation	8,751	hr/yr
Number of starts	10	starts/yr
Operational life	1.71	yr
Capacity factor	82.7	%
Fixed generation cost	0.492	\$/hr
Marginal generation	0.200	\$/kWh

Quantity	Value	Units
Electrical production	21,743	kWh/yr
Mean electrical output	2.48	kW
Min. electrical output	0.900	kW
Max. electrical output	3.00	kW

Quantity	Value	Units
Fuel consumption	7,536	L/yr
Specific fuel consumption	0.347	L/kWh
Fuel energy input	74,158	kWh/yr
Mean electrical efficiency	29.3	%



HOMER - [FOB with renewablesCaseb]

File View Inputs Outputs Window Help

Equipment to consider .dd/Remove

Resources

- Solar Resource
- Wind Resource
- Diesel

Other

- Economics
- System Control
- Emissions
- Constraints

AC

DC

Generator 1

RDISS+FP Suite
48 kWh/d
3.9 kW peak

ECP
10 kWh/d
1.9 kW peak

Converter

PV

\$W Whisper 200

L16P

Sensitivity Results | Optimization Results

Double click on a system below for optimization

						PV (kW)	W200	Gen (kW)
						5	3	3

PV Inputs

File Edit Help



Enter at least one size and capital cost value in the Costs table. Include all costs associated with the PV (photovoltaic) system, including modules, mounting hardware, and installation. As it searches for the optimal system, HOMER considers each PV array capacity in the Sizes to Consider table.

Note that by default, HOMER sets the slope value equal to the latitude from the Solar Resource Inputs window.


Hold the pointer over an element or click Help for more information.

Costs

Size (kW)	Capital (\$)	Replacement (\$)	D&M (\$/yr)
5.000	15000	18000	0
10.000	30000	36000	0
20.000	60000	72000	0
	{.}	{.}	{.}

Sizes to consider

Size (kW)
5.000
10.000
20.000



Properties

Output current AC DC

Lifetime (years) {.}

Derating factor (%) {.}

Slope (degrees) {.}

Azimuth (degrees W of S) {.}

Ground reflectance (%) {.}

Advanced

Tracking system

Consider effect of temperature

Temperature coeff. of power (%/°C) {.}

Nominal operating cell temp. (°C) {.}

Efficiency at std. test conditions (%) {.}

Help

Cancel

OK

Solar Resource Inputs

File Edit Help



HOMER uses the solar resource inputs to calculate the PV array power for each hour of the year. Enter the latitude, and either an average daily radiation value or an average clearness index for each month. HOMER uses the latitude value to calculate the average daily radiation from the clearness index and vice-versa.

Hold the pointer over an element or click Help for more information.

Location

Latitude North SouthLongitude East West

Time zone

(GMT+04:30) Afghanistan

Data source: Enter monthly averages Import time series data file


Get Data Via Internet

Baseline data

Type monthly average radiation or clearness index values into the table or import a data file.

Month	Clearness Index	Daily Radiation (kWh/m ² /d)
January	0.581	2.955
February	0.582	3.731
March	0.570	4.690
April	0.588	5.856
May	0.622	6.909
June	0.667	7.692
July	0.672	7.587
August	0.673	6.968
September	0.671	5.902
October	0.676	4.688
November	0.625	3.359
December	0.533	2.492

Average: 0.630 5.243

Scaled annual average (kWh/m²/d) 

Data Source...

Plot...

Export...

Help

Cancel

OK

The screenshot displays the HOMER software interface for a project titled "HOMER - [FOB with renewablesCaseb]". The interface includes a menu bar (File, View, Inputs, Outputs, Window, Help) and a toolbar with various icons. The main area shows a power system diagram with two vertical buses: AC and DC. The AC bus is connected to a Generator 1 and a RDISS+FP Suite. The DC bus is connected to a PV array, a SW Whisper 200 wind turbine, and an L16P battery. A Converter is connected between the AC and DC buses. The RDISS+FP Suite is specified with 48 kWh/d and 3.9 kW peak. The ECP is specified with 10 kWh/d and 1.9 kW peak. A "Calculate" button is visible in the top right. Below the diagram, there are sections for "Resources" (Solar, Wind, Diesel) and "Other" (Economics, System Control, Emissions, Constraints). On the right side, there are tabs for "Sensitivity Results" and "Optimization Results", and a table with the following data:

Double click on a system below for optimization

	PV (kW)	W200	Gen (kW)
	5	3	3

Wind Turbine Inputs

File Edit Help



Choose a wind turbine type and enter at least one quantity and capital cost value in the Costs table. Include the cost of the tower, controller, wiring, installation, and labor. As it searches for the optimal system, HOMER considers each quantity in the Sizes to Consider table.

Hold the pointer over an element or click Help for more information.

Turbine type

Turbine properties

Abbreviation: W200 (used for column headings)
 Rated power: 1 kW DC
 Manufacturer: Southwest Windpower
 Website: www.windenergy.com



Costs


Quantity	Capital (\$)	Replacement (\$)	O&M (\$/yr)
1	4000	2000	50
2	8000	4000	100
3	12000	6000	150

Sizes to consider

Quantity
1
2
3

Other

Lifetime (yrs)
 Hub height (m)



Wind Resource Inputs

File Edit Help



HOMER uses wind resource inputs to calculate the wind turbine power each hour of the year. Enter the average wind speed for each month. For calculations, HOMER uses scaled data: baseline data scaled up or down to the scaled annual average value. The advanced parameters allow you to control how HOMER generates the 8760 hourly values from the 12 monthly values in the table.


Hold the pointer over an element or click Help for more information.

Data source: Enter monthly averages Import time series data file

Baseline data (from Central Asia Plains.wnd)

Month	Wind Speed (m/s)
January	4.181
February	5.153
March	5.251
April	6.240
May	6.295
June	5.125
July	4.533
August	5.427
September	4.986
October	5.632
November	4.282
December	4.235

Annual average: 5.111



Other parameters

Time step (minutes)

Altitude (m above sea level)

Anemometer height (m)

Advanced parameters

Weibull k

1-hr autocorrelation factor

Diurnal pattern strength

Hour of peak windspeed

Scaled annual average (m/s)

Simulation Results

System Architecture: 5 kW PV 40 Trojan L16P Cycle Charging
 3 SW Whisper 200 10 kW Inverter
 3 kW Generator 1 10 kW Rectifier


Total NPC: \$ 89,367
 Levelized COE: \$ 0.330/kWh
 Operating Cost: \$ 3,940/yr

Cost Summary | Cash Flow | Electrical | PV | W200 | Gen | Battery | Converter | Emissions | Time Series

Quantity	Value	Units
Hours of operation	1,862	hr/yr
Number of starts	73	starts/yr
Operational life	8.06	yr
Capacity factor	20.0	%
Fixed generation cost	0.492	\$/hr
Marginal generation	0.200	\$/kWh

Quantity	Value	Units
Electrical production	5,262	kWh/yr
Mean electrical output	2.83	kW
Min. electrical output	0.900	kW
Max. electrical output	3.00	kW

Quantity	Value	Units
Fuel consumption	1,762	L/yr
Specific fuel consumption	0.335	L/kWh
Fuel energy input	17,343	kWh/yr
Mean electrical efficiency	30.3	%



System Architecture: 5 kW PV 40 Trojan L16P Cycle Charging
 3 SW Whisper 200 10 kW Inverter
 3 kW Generator 1 10 kW Rectifier

Total NPC: \$ 89,367
 Levelized COE: \$ 0.330/kWh
 Operating Cost: \$ 3,940/yr

UNCLASSIFIED


Cost Summary | Cash Flow | Electrical | PV | W200 | Gen | Battery | Converter | Emissions | Time Series

Production	kWh/yr	%
PV array	11,907	46
Wind turbines	8,465	33
Generator 1	5,262	21
Total	25,634	100

Consumption	kWh/yr	%
AC primary load	21,199	100
Total	21,199	100

Quantity	kWh/yr	%
Excess electricity	1,152	4.50
Unmet electricity	7.05	0.03
Capacity shortage	13.8	0.06

Quantity	Value
Renewable fraction	0.752
Max. renew. penetratic	1,498 %



Simulation Results


System Architecture: 5 kW PV 40 Trojan L16P Cycle Charging
 3 SW Whisper 200 10 kW Inverter
 3 kW Generator 1 10 kW Rectifier

Cost Summary | Cash Flow | Electrical | PV | W200 | Gen | Battery | Converter | Emissions | Time Series


Pollutant	Emissions (kg/yr)
Carbon dioxide	4,641
Carbon monoxide	11.5
Unburned hydrocarbons	1.27
Particulate matter	0.864
Sulfur dioxide	9.32
Nitrogen oxides	102

UNCLASSIFIED



Annual Generator Diesel Consumption Reduction



- Based upon an initial Homer assessment for a single Army TQG with associated simplifying assumptions
- Assumes fully burdened cost of diesel fuel of \$20/gallon
- Initial investment and ROI needs to be further assessed to determine the practicality of realizing these levels of reduction



VR Forces
3d simulation toolset



20 MW PV Generating Plant

DesignBase
High fidelity energy system/network analysis





Energy & Environment Lab